



ADDENDUM NO. 1

DATE: January 10, 2021

PROJECT NO: 043866.050

PROJECT: City of Fruitland Park – Urick Street Force Main Extension

ALL PROSPECTIVE BIDDERS ARE HEREBY NOTIFIED OF THE CHANGES OR ALTERATIONS IN THE ABOVE-REFERENCED PROJECT

Changes to Plans/Specifications:

1. Contractor shall be required to utilize the most current Davis-Bacon wages and reporting.
2. Permax-CTF may be used as an alternative to Protecto 401.
3. Fusible PVC will not be accepted as an alternative to HDPE due to County right-of-way requirements.

ALL BIDDERS ARE REQUESTED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY SIGNING BELOW AND SUBMITTING THE BID.

ACKNOWLEDGE RECEIPT- ADDENDUM NO. 1

NAME OF BIDDER _____

SIGNATURE _____



TITLE _____ DATE _____