

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for PWS 3350427 City of Fruitland Park

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During July 2023 we did not monitor for disinfection by-products and therefore cannot be sure of the quality of our drinking water during that time.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

What should I do?

There is nothing you need to do at this time.

What happened? What is being done?

Original samples taken in July were mixed in with contaminated bottles. All bottles were disposed of, including the Fruitland Park disinfection by-products. Re-sampling was late due to administrative oversight. We have since taken the required samples on September 13, 2023. The results were satisfactory; no detection of the contaminant.

For more information, please contact A.T. Environmental Services at 352-351-8242.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the City of Fruitland Park.

State Water System ID#: 3350427

Date distributed: 10/18/2023

Any questions, please contact the public works department at (352) 360-6795.